

**ਦਫਤਰ : ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਮੰਡਲ, ਗਿੱਦੜਬਾਹਾ
ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ, (ਭ ਤੇ ਮ) ਸ਼ਾਖਾ**

Only via E-mail/ Regd. Post/ By Hand

ਵੱਲ,

ਪ੍ਰਿੰਸੀਪਲ,

ਭਾਈ ਮੋਹਰੀ ਜੀ ਮੈਮੋਰੀਅਲ ਸੀਨੀਅਰ ਸੈਕੰਡਰੀ ਸਕੂਲ,

ਪਿੰਡ- ਗੁਰੂਸਰ, ਜਿਲਾ - ਸ਼੍ਰੀ ਮੁਕਤਸਰ ਸਾਹਿਬ।

ਨੰਬਰ: DB/ 256

ਮਿਤੀ: 25/04/24

ਵਿਸ਼ਾ: ਸਕੂਲ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਸਾਲ 2024-25 ਜਾਰੀ ਕਰਨ ਸਬੰਧੀ।

ਹਵਾਲਾ: ਆਪ ਦਾ ਪੱਤਰ ਨੰਬਰ: 22/BMJ/24 ਮਿਤੀ 09.04.2024 ਦੇ ਸਬੰਧ ਵਿੱਚ।

ਉਪਰੋਕਤ ਵਿਸ਼ੇ ਅਤੇ ਹਵਾਲੇ ਅਧੀਨ ਪੱਤਰ ਦੇ ਸਬੰਧ ਵਿੱਚ ਆਪ ਦੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਤਕ ਉਪ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਗਿੱਦੜਬਾਹਾ ਦਫਤਰ ਵੱਲੋਂ ਕਰ ਲਿਆ ਗਿਆ ਹੈ। ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ ਦੇ ਦਫਤਰ ਵੱਲੋਂ ਕੀਤੀ ਗਈ ਸਿਫਾਰਿਸ਼ ਅਤੇ ਪ੍ਰੋਫਾਰਮੇ ਦੇ ਕਾਲਮ ਨੰਬਰ 13 ਅਤੇ 14 ਸਬੰਧੀ ਦਫਤਰ ਫਾਇਰ ਸਟੇਸ਼ਨ ਗਿੱਦੜਬਾਹਾ ਵੱਲੋਂ NOC No. 1602-88780-Fire/66415 ਮਿਤੀ 12.04.2024 ਰਾਹੀਂ ਜਾਰੀ ਕੀਤੇ ਫਾਇਰ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦੇ ਆਧਾਰ ਤੇ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸਬੰਧੀ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਮਿਤੀ 31.03.2025 ਤੱਕ ਜਾਰੀ ਕੀਤਾ ਜਾਂਦਾ ਹੈ। ਇੱਥੇ ਇਹ ਵੀ ਸਪਸ਼ਟ ਕੀਤਾ ਜਾਂਦਾ ਹੈ ਕਿ ਇਸ ਪੱਤਰ/ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦਾ ਸਕੂਲ ਦੀ ਜਗ੍ਹਾ ਦੀ ਮਲਕੀਅਤ ਨਾਲ ਕੋਈ ਸਬੰਧ ਨਹੀਂ ਹੈ। (ਨੋਟ: ਸਾਲ 2025-26 ਲਈ ਬਿਲਡਿੰਗ ਸੇਫਟੀ ਸਰਟੀਫਿਕੇਟ ਦਾ ਕੇਸ ਮਿਤੀ 01.04.2025 ਤੋਂ ਪਹਿਲਾਂ ਪਹਿਲਾਂ ਅਪਲਾਈ ਕਰਨਾ ਸਕੂਲ ਮੁਖੀ ਦੀ ਜ਼ਿੰਮੇਵਾਰੀ ਹੋਵੇਗੀ।)

ਨੱਥੀ/ਸਰਟੀਫਿਕੇਟ

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਗਿੱਦੜਬਾਹਾ

ਪਿੱਠ ਅੰਕਣ ਨੰ :DB/

ਮਿਤੀ:

ਉਪਰੋਕਤ ਦਾ ਉਤਰਾ

1. ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਪ੍ਰਾਤਕ ਉਪ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਗਿੱਦੜਬਾਹਾ ਨੂੰ ਉਹਨਾਂ ਵੱਲੋਂ ਪੱਤਰ ਨੰਬਰ 57 ਮਿਤੀ 24.04.2024 ਰਾਹੀਂ ਕੀਤੀ ਗਈ ਸਿਫਾਰਿਸ਼ ਦੇ ਆਧਾਰ ਤੇ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ ਅਤੇ ਲਿਖਿਆ ਜਾਂਦਾ ਹੈ ਕਿ ਉਕਤ ਬਿਲਡਿੰਗ ਦੀ ਹਰ ਸਾਲ ਇੰਸਪੈਕਸ਼ਨ ਕੀਤੀ ਜਾਵੇ ਅਤੇ ਲੋੜੀਂਦੀ ਰਿਪੋਰਟ ਇਸ ਦਫਤਰ ਨੂੰ ਭੇਜੀ ਜਾਵੇ। ਮੰਡਲ ਲੋਕਾ ਅਫਸਰ, ਉਸਾਰੀ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਗਿੱਦੜਬਾਹਾ ਨੂੰ ਸੂਚਨਾ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਉਸਾਰੀ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਗਿੱਦੜਬਾਹਾ।

- d) Weather cooking of food is done at a safe place.
- e) Weather any Thatch combustible material has been used.
14. Requirement for Fire Protection Arrangements under NBC

Part-IV

(For Building height less than 15 metre)

- a) Weather Hose Reel provided. : Yes / No
- b) Weather down comer provided. : Yes / No
- c) Weather Automatic sprinkler provided. : Yes / No
- d) Weather underground static water storage tank of capacity 50,000 Ltr. (if covered area exceeds 1500 sqm.) : Yes / No
- e) Weather over Head tank of capacity 10,000 Ltr. Exists (in case of hose reel) 20,000 Ltr. : Yes / No
- f) Weather one electric and one deisel pump of capacity pressure of capacity 1620 LPM exist near underground static tank. : Yes / No
- g) Weather a pump 3 kg/ cum pressure & 450 / 500 LPM exist near over head tank. : Yes / No

checked

Signature with Stamp of the seal of the School / Institution.

PART-II

(To be filled by the S.D.E. of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated 29.04.2024..... And have visually inspected it from safety and find it fit for normal use as school buildings.
- b) In case any addition / alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls / foundation or sagging or roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) upto 21 March 2025

Engineer Signed

Sub Divisional Engineer,

Sub Divn. PWD (B&R) Br.

Sub Divisional Engineer,

Sub Divn. PWD B&R Br.

Gidderbaha

PROFORMA FOR THE SAFETY OF SCHOOL BUILDING

PART-I

(To be filled by the Head of School / Institution)

1. Name of the School Bhai Mohanji Memorial Public Senior Secondary School

2. Location VPO - GURUSAR

3. Plot Area 106178 SQ.FT.

4. Plinth Area 22345 SQ.FT.

5. Number of Storeys 2 STOREYS

6. Year of Construction of Building 2001 to 2016

7. If the building has been constructed under the supervision

of the qualified Engineer, the following details may be

given :-

a) Name of the Engineer with qualification. GURMAIL SINGH SIDHU

b) Address of Engineer. GURU NANAK NAGAR GIDDERDAH

c) Set of structural drawings used in the construction, if available NOT AVAILABLE

d) Name & Address of architect with qualification. GURMAIL SINGH SIDHU (B.TECH - CIVIL)

8. Whether the building has been constructed for the purpose.

a) School

☒ Yes / ☐ No

b) Residential Purpose and converted for use as a School.

☐ Yes / ☒ No

9. Materials used for roofs

a) R.C.C. Slabs / R.B.C. Slabs.

☒ Yes / ☐ No

b) R.S. Joists & Battons.

☐ Yes / ☒ No

c) Wooden joists & Battons.

☐ Yes / ☒ No

10. Materials used for walls.

a) Mud Mortar.

☐ Yes / ☒ No

b) Cement Mortar.

☒ Yes / ☐ No

c) Lime Mortar.

☒ Yes / ☐ No

11. Flooring.

a) Conglomerate.

☒ Yes / ☐ No

b) Terrazo.

☐ Yes / ☒ No

c) Brick Paving.

☐ Yes / ☒ No

12. A details drawing indicating dimensions of the rooms

alongwith size and location of doors and windows.

☒ Yes / ☐ No

(Attached)

13. FOR FIRE SAFETY.

a) Whether the width of the staircase is 1.5 mtr.

☒ Yes / ☐ No

b) Whether portable fire extinguisher exists.

☒ Yes / ☐ No

c) Whether School building is free from inflammable & toxic material

☒ Yes / ☐ No

(Contd...2..)


Principal
Bhai Mohanji Memorial Public
Senior Secondary School